REGIONAL DISTRICT OF NANAIMO

REQUEST FOR PROPOSALS No. 22-035

GNPCC Dissolved Air Thickening Polymer Supply

Addendum 2
Issued: May 25, 2022

Closing Date & Time: on or before 3:00 PM Pacific Time on May 30, 2022

This addendum shall be read in conjunction with and considered as an integral part of the Request for Proposal. Revisions supersede the information contained in the original Proposal or previously issued Addendum. No consideration will be allowed for any extras due to any Proponent not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

Tender Addendum

DELETE: **Closing Date & Time: on or before 3:00 PM Pacific Time on May 25, 2022**

ADD: **Closing Date & Time: on or before 3:00 PM Pacific Time on May 30, 2022**

Questions and Answers

This following is a compilation of questions received from possible proponents up to 3:00 pm on Wednesday, May 25, 2022, and the answers to these questions

Q1. The RFP is asking for "Recommended Dosing Rate at GNPCC (dose/dry ton solid). To calculate that number, we need the TSS (usually in %) for the incoming/influent sludge into the DAF system. Can you send me that information please?

A1. The Total Suspended Solids in the Waste Activated Sludge (WAS) is not typically tested. However, the sludge has similar characteristics to the Mixed Liquor at GNPCC which has a TSS level of 2400 mg/L (0.24%).

End of Addendum 2