REGIONAL DISTRICT OF NANAIMO

REQUEST FOR TENDER No. 22-050

Boultbee Community Park Improvements

Addendum 1
Issued: June 9, 2022

Closing Date & Time: on or before 3:00 PM Pacific Time on June 15, 2022

This addendum shall be read in conjunction with and considered as an integral part of the Request for Tender. Revisions supersede the information contained in the original Tender or previously issued Addendum. No consideration will be allowed for any extras due to any Vendor not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

Question #1
Part 6 (Page 6 of 34) states - A bid bond is not required but Part 15 - 15.2 (page 11 of 34) states the successful tender should submit a performance and labour and material bond.

Can you please let us know if a bond is required for the project or not?

Response #1
Bidders are not required to submit a bid bond. The successful proponent will be required to submit a Performance Bond, and Labour and Material Bond in accordance with the bid documents.

Question #2
What thickness of topsoil is required for the restoration line item (note 18 on drawings)?

Response #2
100mm thickness of topsoil is required.

End of Addendum 1