REQUEST FOR TENDER No. 22-068

Lions Community Park Playground Project

Addendum 1
Issued: July 26, 2022

Closing Date & Time: on or before 3:00 PM Pacific Time on August 18, 2022

This addendum shall be read in conjunction with and considered as an integral part of the Request for Tender. Revisions supersede the information contained in the original Tender or previously issued Addendum. No consideration will be allowed for any extras due to any Vendor not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

Questions & Answers

Q1. Will you consider comparable/alternative playground equipment for Tender No. 22-068 to the specified LSI Venti, Motion, Swings.

A1. No, alternatives for the playground equipment are not being considered for this project.

Q2. The Catch Basin Manhole Detail on the engineering drawings shows a 1.2m diameter asphalt dish around the catch basin. Can this be changed to concrete or eliminated?

A2. Concrete or asphalt are both acceptable for the dish around the manhole.

Q3. What type and extents of construction security fencing required for the project?

A3. Metal fencing ("Modu-Loc" or equivalent) is required around the entire construction site. Fencing to be a minimum of 1.8m in height.

Q4. For Provisional Item G2, where are the irrigation controls and valve box to be located on site?

A4. Irrigation controls and valve box to be located near the existing washroom building. Exact location to be determined on site with the successful bidder.

End of Addendum 1