REQUEST FOR PROPOSALS NO. 22-075
Addendum 1

Wastewater Outfall Inspection Services

Issued: Wednesday, September 14, 2022

Closing Date & Time: on or before 3:00 PM Pacific Time on September 22, 2022

This addendum shall be read in conjunction with and considered as an integral part of the Request for Proposals. Revisions supersede the information contained in the original Request for Proposals. No consideration will be allowed for any extras due to any Proponent not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

Tender Addendum:

DELETE: Closing Date & Time: on or before 3:00 PM Pacific Time on September 20, 2022

ADD: Closing Date & Time: on or before 3:00 PM Pacific Time on September 22, 2022

Questions and Answers

This following is a compilation of questions received from possible proponents up to 12:00 pm on September 14, 2022, and the answers to these questions:

Q1. Are drawings listed on page 12 of the RFP available for review?

A1. The drawings listed on page 12 are saved on the RDN Cloud site. Please contact the RFP Contact for Questions to obtain the access link.

Q2. Is an example of previous report available for review of format expected?

A2. The four reports from the inspection in 2017 are saved on the RDN Cloud site. Please contact the RFP Contact for Questions to obtain the access link.

Q3. Do you require a Registered Engineer to signoff on reports provided?

A3. The condition assessment on the outfall needs to be completed by a qualified person with experience in marine outfall condition assessment.

Reports prepared and signed off by a Qualified Professional (such as a Professional Engineer or other self-regulated professional under the *Environmental Management Act*) with experience in marine outfall condition assessment would receive a higher technical score.

Please provide background on the qualified person's experience, education, and professional designation in your proposal submission.

Q4. It is our experience that visibility would be more optimal in the February/March time frame, are you opened to inspection in this time frame to keep cost down?

A4. The RDN's wastewater permits require this inspection to be completed on a 5-year interval. The RDN would prefer to schedule the inspection prior to the end of 2022 due to this condition in our permits.

End of Addendum 1