REQUEST FOR PROPOSAL No. 23-010

Supply and Install of Prefabricated Campground Office Building

Addendum 1
Issued: February 14, 2023

Closing Date & Time: on or before 3:00 PM Pacific Time on March 7, 2023

This addendum shall be read in conjunction with and considered as an integral part of the Request for Proposal. Revisions supersede the information contained in the original Request for Proposal or previously issued Addendum. No consideration will be allowed for any extras due to any Vendor not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

Question #1

- Height of concrete pad
    - Just planning for skirting and stair height

Response #1
Concrete pad is level with surrounding grade.

Question #2

- Lights are to be surface mount but not conduit correct?

Response #2
Correct.

Question #3

- No sink in washroom – hand sanitizer station, okay?
    - Any accessories we are to supply

Response #3
Hand washing sink is required in the washroom. Proponent to supply the following accessories for the washroom: toilet, toilet seat, toilet paper holder, sink, faucet.

Question #4

- Do you want a small security window on the customer service side and none on the office storage

Response #4
Correct. Approximate window sizing and placement is noted in Appendix 1.

End of Addendum 1