REQUEST FOR PROPOSAL No. 23-010

Supply and Install of Prefabricated Campground Office Building

Addendum 2
Issued: February 21, 2023

Closing Date & Time: on or before 3:00 PM Pacific Time on March 7, 2023

This addendum shall be read in conjunction with and considered as an integral part of the Request for Proposal. Revisions supersede the information contained in the original Request for Proposal or previously issued Addendum. No consideration will be allowed for any extras due to any Vendor not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

Question #1
On the concrete pad supplied by client for the building. Where are the utilities located that you would be tying into our building.

Response #1
See attached for Appendix 2.

Question #2
When delivering and placing the building on site, can the existing shipping container storage buildings be temporarily moved?

Response #2
Yes, the shipping containers can be relocated if needed to make room for delivering and installing the new campground office building. Moving the shipping containers and returning them to their original position would be the responsibility of the contractor.

Question #3
Can the campground access road be closed during building delivery and installation?

Response #3
The access road must remain open as much as possible during building installation in case of emergency.

Question #4
Who is responsible for removing the existing ATCO office building?

Response #4
The RDN will coordinate removal of the ATCO office building prior to delivery of the new campground office.

Question #5
Is there any overhang on the roof of the new building?


Response #5
Yes, a 12” (30cm) overhang is required on all sides. Soffit and facia colour to match side and rear siding colour.

Question #6
RFP document states “Provide two dedicated RV outlets (30 or 50 amp) on rear of building”. Could you please specify which outlet size is required?

Response #6
One 30-amp outlet and one 50-amp outlet are required.

End of Addendum 2

APPENDIX 2: UTILITY AND BUILDING LOCATIONS



NOTE: ALL DIMENSIONS ARE APPROXIMATE.

REGIONAL DISTRICT OF NANAIMO