REGIONAL DISTRICT OF NANAIMO

REQUEST FOR PROPOSALS No. 23-048

Melrose Terrace Reservoir Replacement Project

Addendum 2
Issued: August 23, 2023

Closing Date & Time: on or before 3:00 PM Pacific Time on August 31st, 2023

This addendum shall be read in conjunction with and considered as an integral part of the Request for Proposal. Revisions supersede the information contained in the original Proposal or previously issued Addendum. No consideration will be allowed for any extras due to any Proponent not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

Questions and Answers:

Question 1: Please confirm if the Risk Category IV, as per section 5.2 of AWWA D103-19, needs to be considered for the design of the tank and foundation.

Answer 1: The tank structure and the foundation need to be designed with Risk Category **III**, as given in the Section 5.2 of AWWA D103-19.

End of Addendum 2